

## APPENDIX E

### Avista Utilities Interconnection Checklist

- Submit an application to the Avista Utilities
  - ✓ Interconnection inverter must be UL 1741 Listed
  - ✓ Electrical schematic drawing must be included
  - ✓ Include provisions for a lockable visible disconnect if required by the Avista Utilities or local jurisdiction.
- Send to: Dan Knutson, Avista, PO Box 3727, Spokane, WA 99220-3727, (509) 495-4204
- Receive written design approval from the Avista Utilities
- Get an electrical permit from Washington State L&I @ \_\_\_\_\_. Follow the National Electric Code (NEC) as required.
- Complete the installation.
- Customer must install a separate meter base to qualify for incentives (Avista will provide and install a production meter that will measure your generation).
- Get inspections from a state electrical inspector and the Avista Utilities (call Avista Utilities for inspection at (509) 495-4204).
- Avista Utilities installs new bi-directional meter and adjusts rate schedule #\_\_\_ net metering.
- Start generating power